



City of Hurricane

IRC Equipment and Duct Plan

IRC – M1401.3 Sizing

Heating and cooling *equipment* and *appliances* shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other *approved* heating and cooling calculation methodologies

IRC – M1601.1 Duct Design

Duct systems serving heating, cooling and ventilation equipment shall be installed in accordance with the provisions of this section and ACCA Manual D or other approved methods.

Installers Company:	Phone #	
License #	Permit #	
Subdivision:	Lot #	Phase #
Address:		

I hereby certify that the heating and cooling equipment, appliances and ducts are sized and designed in accordance with ACCA Manual J for heating and cooling loads, ACCA Manual S for equipment sizing and ACCA Manual D for duct sizing, or other approved calculation methodologies.

Installer's Signature: _____ Date: _____

Please print your name: _____

Approved by: Building Inspector	Comments
------------------------------------	----------